



NOTIFIED BODY No. 1488
INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT

ul. FILTROWA 1, 00-611 WARSZAWA
ph.: +48 (22) 57 96 167, +48 (22) 57 96 168, fax: +48 (22) 57 96 295
e-mail: certyfikacja@itb.pl, www.itb.pl



CERTIFICATE OF CONSTANCY OF PERFORMANCE
1488-CPR-0661/W

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fire damper type SXN-O-E and SXN-O-S

fire resistance class according to EN 13501-3:2005+A1:2009:

EI 120 (ve ho i↔o) S

general identification, intended use, essential characteristics and parameters are described in Annex No. Z-1488-CPR-0661/W which is an integral part of this certificate

placed on the market under the name or trade mark of:

AEROPRODUKT ZRT.
Szegedi út 1
6640 Csongrád
Hungary

and produced in the manufacturing plant:

48 – 535

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 15650:2010

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 25.04.2018 and will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DIRECTOR
of Instytut Techniki Budowlanej

Robert Geryło, Ph. D.

Warsaw, 25.04.2018